CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No : TC- 5548

TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Date: 28/08/2018

Lab ID	:	**CP-2018-08-02-07**
Customer	:	Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.
Address	:	Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Providing and construction of CC road at Urdu school opp road and cross roads at Dasarahalli in Ward No.15
Agency	:	Nandi Enterprises (Pro. P Vijaya Babu) No 1504 4th 'C' Main, 2nd Stage WOC Road, Bangalore-560086
Customer's Reference	:	EE/DD/WO/13/18-19
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	02-08-18
Sample ID No	:	2018-08-02-07 /02
Customer ID	:	Drain Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	28/08/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	31/07/2018	28/08/2018	149.63 X 151.54 X 150.03	22675	8.175	507.9	22.4	22.7
2	Drain Concrete	M20	31/07/2018	28/08/2018	149.66 X 151.44 X 149.87	22665	8.198	523.6	23.1	
3	Drain Concrete	M20	31/07/2018	28/08/2018	150.23 X 151.02 X 149.63	22688	8.155	512.7	22.6	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಧಿಯಂತರು
ಟಿ.ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬೆಂಗಳೂರು

****End of Report****

FOR CIVIL Pro.

P KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE
Sig.....
Date.....

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Scanned by CamScanner

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID	:	**CP-2018-08-02-07** **Date: 07/08/2018**
Customer	:	Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.
Address	:	Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Providing and construction of CC road at Urdu school opp road and cross roads at Dasarahalli in Ward No.15
Agency	:	Nandi Enterprises (Pro. P Vijaya Babu) No 1504 4th 'C' Main, 2nd Stage WOC Road, Bangalore-560086
Customer's Reference	:	EE/DD/WO/13/18-19
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	02-08-18
Sample ID No	:	2018-08-02-07 /01
Customer ID	:	Drain Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	07/08/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	31/07/2018	07/08/2018	149.63 X 150.75 X 150.75	22557	8.163	408.3	18.1	18.1
2	Drain Concrete	M20	31/07/2018	07/08/2018	149.63 X 150.86 X 151.02	22573	8.172	404.1	17.9	
3	Drain Concrete	M20	31/07/2018	07/08/2018	150.75 X 149.66 X 151.32	22561	8.166	412.9	18.3	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರ
ಬಿ.ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬೆಂಗಳೂರು

****End of Report****

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Scanned by CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No : TC- 5548

TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Lab ID	:	**CP-2018-08-02-07**
Customer	:	Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore. **Date: 28/08/2018**
Address	:	Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Providing and construction of CC road at Urdu school opp road and cross roads at Dasarahalli in Ward No.15
Agency	:	Nandi Enterprises (Pro. P Vijaya Babu) No 1504 4th 'C' Main, 2nd Stage WOC Road, Bangalore-560086
Customer's Reference	:	EE/DD/WO/13/18-19
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	02-08-18
Sample ID No	:	2018-08-02-07 /02
Customer ID	:	Drain Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	28/08/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	31/07/2018	28/08/2018	151.07 X 151.88 X 150.22	22945	8.213	502.5	21.9	22.4
2	Drain Concrete	M20	31/07/2018	28/08/2018	151.63 X 150.75 X 150.96	22858	8.166	514.3	22.5	
3	Drain Concrete	M20	31/07/2018	28/08/2018	150.58 X 151.25 X 149.63	22775	8.175	517.0	22.7	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID	:	**CP-2018-08-02-07** **Date: 07/08/2018**
Customer	:	Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.
Address	:	Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Providing and construction of CC road at Urdu school opp road and cross roads at Dasarahalli in Ward No.15
Agency	:	Nandi Enterprises (Pro. P Vijaya Babu) No 1504 4th 'C' Main, 2nd Stage WOC Road, Bangalore-560086
Customer's Reference	:	EE/DD/WO/13/18-19
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	02-08-18
Sample ID No	:	2018-08-02-07 /01
Customer ID	:	Drain Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 07/08/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	31/07/2018	07/08/2018	150.75 X 150.21 X 150.09	22644	8.156	421.2	18.6	18.4
2	Drain Concrete	M20	31/07/2018	07/08/2018	150.38 X 150.22 X 150.69	22590	8.163	404.4	17.9	
3	Drain Concrete	M20	31/07/2018	07/08/2018	150.76 X 150.63 X 151.45	22709	8.175	422.4	18.6	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಟಿ.ದಾಸರಹಳ್ಳಿ
ಬಾಗಲಗುಂಟೆ
ಬೆಂಗಳೂರು

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

Scanned by CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID	:	CP-2018-08-02-07 **Date: 28/08/2018**
Customer	:	Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.
Address	:	Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Providing and construction of CC road at Urdu school opp road and cross roads at Dasarahalli in Ward No.15
Agency	:	Nandi Enterprises (Pro. P Vijaya Babu) No 1504 4th 'C' Main, 2nd Stage WOC Road, Bangalore-560086
Customer's Reference	:	EE/DD/WO/13/18-19
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	02-08-18
Sample ID No	:	2018-08-02-07 /02
Customer ID	:	Drain Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	28/08/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	31/07/2018	28/08/2018	151.33 X 150.96 X 150.52	22845	8.126	546.0	23.9	22.9
2	Drain Concrete	M20	31/07/2018	28/08/2018	150.66 X 150.43 X 150.75	22664	8.175	505.4	22.3	
3	Drain Concrete	M20	31/07/2018	28/08/2018	150.96 X 150.75 X 150.75	22757	8.203	512.0	22.5	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO Sig..... Date..... BANGALORE

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner